

<b>1. Survey Date</b>	02/01/2012
<b>2. Unit Name:</b>	Garner towne square fsu
<b>3. Unit #</b>	00678
<b>4. Surveyor Name</b>	Jeff Coke
<b>5. What is the water pressure in this unit?</b>	60
<b>6. Is there a pump in this unit? - Please select answer from list below.</b>	No - Not existing and not needed
<b>7. What type of pump is installed at this unit?</b>	Na
<b>8. Where is the main shut off located?</b>	In knock out
<b>9. Did you take a photo of the shut off location?</b>	Yes
<b>10. Where is the current water filtration system located?</b>	In knock out
<b>11. Did you take a photo of the current water filtration system?</b>	Yes
<b>12. Does this unit currently have a water softener?</b>	No
<b>13. If existing water softener - did you take a photo?</b>	NA - No softener installed at this unit
<b>14. Current Ice Machine Installed:</b>	Other (please specify) Cuber double stack
<b>15. Will we have to remove a shelf in order to install a new system?</b>	No
<b>16. Will there be any special equipment needed for tea lines?</b>	New tea hose
<b>17. Will there be any special equipment needed for the coffee lines?</b>	Extra and im600
<b>18. Will we need to install a SWF?</b>	

Yes
<b>19. Are there high ceilings? Please answer yes or no. (describe height if they are high)</b>
No
<b>20. What is the size and type of piping we are tapping into?</b>
3/4" copper
<b>21. If this is a mall, are there doors from the unit leading directly to the outside?</b>
Na
<b>22. Please list the type of equipment to order and install in this unit.</b>
Seleto IM600 (500231, 3SEL044) Seleto IM600 (500231, 3SEL044) Selecto T-1 New Gen Filtration System (500191, 3SEL035)
<b>23. Please state recommended location for new water filtration system.</b>
Above knock out
<b>24. Please list any other challenges with new install.</b>
None