

Survey Response For: CFA WF Pre - Survey (Open)

Response Data	Contact Data	
Started: 02/01/12 2:42PM	Email Address:	CustomData3:
Completed: 02/01/12 2:45PM	First Name:	CustomData4:
Time Spent: 2 Min 35 Sec	Last Name:	CustomData5:
IP Address: 97.233.190.19	CustomData1:	CustomData6:
Deployed: Email Program	CustomData2:	

1. Survey Date
02/01/2012
2. Unit Name:
Wilson fsu
3. Unit #
00793
4. Surveyor Name
Jeff Coke
5. What is the water pressure in this unit?
40
6. Is there a pump in this unit? - Please select answer from list below.
No - Please order one for this unit
7. What type of pump is installed at this unit?
None
8. Where is the main shut off located?
On knock out
9. Did you take a photo of the shut off location?
Yes
10. Where is the current water filtration system located?
In knock out
11. Did you take a photo of the current water filtration system?
Yes
12. Does this unit currently have a water softener?
No
13. If existing water softener - did you take a photo?
NA - No softener installed at this unit
14. Current Ice Machine Installed:
Cubelet
15. Will we have to remove a shelf in order to install a new system?
Yes
16. Will there be any special equipment needed for tea lines?
No
17. Will there be any special equipment needed for the coffee lines?

No
18. Will we need to install a SWF?
No
19. Are there high ceilings? Please answer yes or no. (describe height if they are high)
No
20. What is the size and type of piping we are tapping into?
1 1/2" copper 3/4" copper
21. If this is a mall, are there doors from the unit leading directly to the outside?
Na
22. Please list the type of equipment to order and install in this unit.
Selecto T-1 New Gen Filtration System (500191, 3SEL035)
23. Please state recommended location for new water filtration system.
Above knock out
24. Please list any other challenges with new install.
None

Copyright © 2011 SurveySquare.com All Rights Reserved.