

Project Name: CFA # 0898 San Angelo
Design by: Rod Berry

Date: 10/26/2010

Blending Calculations

Raw Water: City

Flow Rate, gpm : 0.15 gpm 9 gph/216 gpd
Conc., mg/l : 1100.0 ppm

Flow through Submicron filters

Treated Water: Filter

Everpure MRS/Conveerted to
Nano Filter Membranes

Flow Rate, gpm : 0.65 gpm 39 gph/936 gpd
Conc., mg/l : 58.0 ppm

Estimated Nano Production

Blended Water:

City/Nano Filters

Flow Rate, gpm : 0.8 gpm 48 gph/1,152 gpd
Conc., mg/l : 250.0 ppm

Total blended production

Reverse Osmosis System Analysis for FILMTEC™ Membranes

ROSA 7.2.1 ConfigDB u392554_129

Project: CFA 0898

Case: 1

Rod Berry, Ultraclear Water

10/25/2010

Project Information:**Case-specific:****System Details**

Feed Flow to Stage 1	2.17 gpm	Pass 1 Permeate Flow	0.65 gpm	Osmotic Pressure:	
Raw Water Flow to System	2.17 gpm	Pass 1 Recovery	30.00 %	Feed	9.32 psig
Feed Pressure	63.85 psig	Feed Temperature	77.0 F	Concentrate	12.90 psig
Flow Factor	0.85	Feed TDS	1124.35 mg/l	Average	11.11 psig
Chem. Dose (100% H2SO4)	0.00 mg/l	Number of Elements	2	Average NDP	46.23 psig
Total Active Area	56.00 ft²	Average Pass 1 Flux	16.72 gfd	Power	0.08 kW
Water Classification: Well Water SDI < 3				Specific Energy	1.93 kWh/kgal

Stage	Element	#PV	#Ele	Feed Flow (gpm)	Feed Press (psig)	Recirc Flow (gpm)	Conc Flow (gpm)	Conc Press (psig)	Perm Flow (gpm)	Avg Flux (gfd)	Perm Press (psig)	Boost Press (psig)	Perm TDS (mg/l)
1	NF90-2540	1	2	2.17	58.85	0.00	1.52	54.60	0.65	16.72	0.00	0.00	57.18

Pass Streams (mg/l as Ion)						
Name	Feed	Adjusted Feed	Concentrate	Permeate		
			Stage 1	Stage 1	Total	
NH4	0.00	0.00	0.00	0.00	0.00	
K	9.00	9.00	12.47	0.91	0.91	
Na	196.21	196.22	273.26	16.47	16.47	
Mg	51.50	51.50	73.10	1.10	1.10	
Ca	93.20	93.20	132.32	1.93	1.93	
Sr	1.99	1.99	2.83	0.04	0.04	
Ba	0.21	0.21	0.30	0.00	0.00	
CO3	1.40	1.40	2.57	0.00	0.00	
HCO3	165.30	165.30	232.47	5.94	5.94	
NO3	0.60	0.60	0.68	0.41	0.41	
Cl	333.00	333.00	464.30	26.68	26.68	
F	0.80	0.80	1.11	0.08	0.08	
SO4	264.00	264.00	375.76	3.28	3.28	
SiO2	7.12	7.12	10.03	0.32	0.32	
Boron	0.00	0.00	0.00	0.00	0.00	
CO2	2.42	2.42	2.82	2.42	2.42	
TDS	1124.34	1124.35	1581.22	57.18	57.18	
pH	7.90	7.90	7.96	6.57	6.57	

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Reverse Osmosis System Analysis for FILMTEC™ Membranes
Project: CFA 0898
Rod Berry, Ultraclear Water

ROSA 7.2.1 ConfigDB u392554_129
Case: 1
10/25/2010

Design Warnings

-None-

Solubility Warnings

Langelier Saturation Index > 0

Stiff & Davis Stability Index > 0

BaSO₄ (% Saturation) > 100%

Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

Stage Details

Stage 1 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.16	0.34	50.30	2.17	1124.35	58.85
2	0.17	0.31	64.74	1.83	1324.18	56.46

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Scaling Calculations

	Raw Water	Adjusted Feed	Concentrate
pH	7.90	7.90	7.96
Langelier Saturation Index	0.48	0.48	0.82
Stiff & Davis Stability Index	0.76	0.76	0.98
Ionic Strength (Molal)	0.02	0.02	0.04
TDS (mg/l)	1124.34	1124.35	1581.22
HCO ₃	165.30	165.30	232.47
CO ₂	2.42	2.42	2.82
CO ₃	1.40	1.40	2.57
CaSO ₄ (% Saturation)	4.75	4.75	8.23
BaSO ₄ (% Saturation)	1828.21	1828.21	2655.86
SrSO ₄ (% Saturation)	7.40	7.40	11.01
CaF ₂ (% Saturation)	7.93	7.93	21.59
SiO ₂ (% Saturation)	5.53	5.53	7.52
Mg(OH) ₂ (% Saturation)	0.01	0.01	0.02

To balance: 0.01 mg/l Na added to feed.