

TECHNICAL SERVICE REPORT

Water Analysis


Customer:	Location:	Date:	PO#:
Chick-fil-A	# 852	2/21/08	304910
Address:		Tested By:	
1245 William D. Tate Ave. Grapevine, TX 76051		AR	
Phone:	Email:	Selecto Contact:	

Recommendation:	
------------------------	--

ANALYTICAL RESULTS

Evaluation of:	Unfiltered Water Sample	Filtered Water Sample	Recommended Max Levels
Fluoride, ppm	0.4	0.4	2 ppm
Chloride, ppm	65	51	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.4	0.4	10 ppm as N
Sulfate, ppm	56	53	250 ppm
Sodium, ppm	51	44	250 ppm
Chloramine	Detected	ND	.5 ppm
Chlorine, ppm	Detected	ND	Detectable
Alkalinity, ppm	125	125	150 ppm
Total Dissolved Solids, ppm	250	240	500 ppm
Hardness, ppm	138	133	100 ppm
pH	7.8	7.8	6.5 – 8.5 ppm
Turbidity	0.00	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



SELECTO SCIENTIFIC
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

www.selectoinc.com
sales@selectoinc.com