

TECHNICAL SERVICE REPORT

Water Analysis

| | | | |
|---|------------------|-------------------------|-------------|
| Customer: | Location: | Date: | PO#: |
| Chick-fil-A | # 2437 | 2/20/08 | 302674 |
| Address: | | Tested By: | |
| 109 Black Horse Pike Audubon, NJ 08106 | | AR | |
| Phone: | Email: | Selecto Contact: | |
| | | | |

| | |
|------------------------|--|
| Recommendation: | |
|------------------------|--|

ANALYTICAL RESULTS

| Evaluation of: | Walmart Water Sample | Staples Water Sample | Recommended Max Levels |
|-----------------------------|----------------------|----------------------|------------------------|
| Fluoride, ppm | ND | ND | 2 ppm |
| Chloride, ppm | 78 | 38 | 250 ppm |
| Nitrite, ppm | ND | ND | 1 ppm as N |
| Nitrate, ppm | 0.8 | 0.9 | 10 ppm as N |
| Sulfate, ppm | 16 | 16 | 250 ppm |
| Sodium, ppm | 59 | 25 | 250 ppm |
| Chloramine | ND | ND | .5 ppm |
| Chlorine, ppm | ND | ND | Detectable |
| Alkalinity, ppm | 50 | 50 | 150 ppm |
| Total Dissolved Solids, ppm | 210 | 140 | 500 ppm |
| Hardness, ppm | 57 | 60 | 100 ppm |
| pH | 6.5 | 6.5 | 6.5 – 8.5 ppm |
| Turbidity | 0.00 | 0.00 | .05 NTU |

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



SELECTO SCIENTIFIC
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

www.selectoinc.com

sales@selectoinc.com