

# TECHNICAL SERVICE REPORT

## Water Analysis

<b>Customer:</b>	<b>Location:</b>	<b>Date:</b>	<b>PO#:</b>
Chick-fil-A	# 1417	2/21/08	304789
<b>Address:</b>		<b>Tested By:</b>	
1105 N. Burleson Blvd. Burleson, TX 76028		AR	
<b>Phone:</b>	<b>Email:</b>	<b>Selecto Contact:</b>	

<b>Recommendation:</b>	
------------------------	--

### ANALYTICAL RESULTS

Evaluation of:	Unfiltered Water Sample	Filtered Water Sample	Recommended Max Levels
Fluoride, ppm	0.6	0.6	2 ppm
Chloride, ppm	48	33	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.5	0.5	10 ppm as N
Sulfate, ppm	32	31	250 ppm
Sodium, ppm	33	23	250 ppm
Chloramine	Detected	ND	.5 ppm
Chlorine, ppm	Detected	ND	Detectable
Alkalinity, ppm	125	125	150 ppm
Total Dissolved Solids, ppm	200	190	500 ppm
Hardness, ppm	167	137	100 ppm
pH	7.4	7.4	6.5 - 8.5 ppm
Turbidity	0.00	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



**SELECTO SCIENTIFIC**  
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

[www.selectoinc.com](http://www.selectoinc.com)  
[sales@selectoinc.com](mailto:sales@selectoinc.com)