

TECHNICAL SERVICE REPORT

Water Analysis

Customer:	Location:	Date:	PO#:
Chick-fil-A	# 1348	2/20/08	305056
Address:		Tested By:	
10916 Parkside Dr. Knoxville, TN 37922		AR	
Phone:	Email:	Selecto Contact:	

Recommendation:	
------------------------	--

ANALYTICAL RESULTS

Evaluation of:	Unfiltered Water Sample	Filtered Water Sample	Recommended Max Levels
Fluoride, ppm	0.1	0.1	2 ppm
Chloride, ppm	44	44	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.7	0.7	10 ppm as N
Sulfate, ppm	15	15	250 ppm
Sodium, ppm	30	30	250 ppm
Chloramine	ND	ND	.5 ppm
Chlorine, ppm	Detected	Detected	Detectable
Alkalinity, ppm	115	115	150 ppm
Total Dissolved Solids, ppm	190	190	500 ppm
Hardness, ppm	113	113	100 ppm
pH	7.5	7.5	6.5 – 8.5 ppm
Turbidity	0.00	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



SELECTO SCIENTIFIC
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

www.selectoinc.com

sales@selectoinc.com