

## TECHNICAL SERVICE REPORT

### Water Analysis

<b>Customer:</b>	<b>Location:</b>	<b>Date:</b>	<b>PO#:</b>
Chick-fil-A	# 851	2/21/08	304780
<b>Address:</b>		<b>Tested By:</b>	
4700 S. Cooper St. Arlington, TX 76017		AR	
<b>Phone:</b>	<b>Email:</b>	<b>Selecto Contact:</b>	

<b>Recommendation:</b>	
------------------------	--

### ANALYTICAL RESULTS

Evaluation of:	Unfiltered Water Sample	Filtered Water Sample	Recommended Max Levels
Fluoride, ppm	0.4	0.4	2 ppm
Chloride, ppm	44	44	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.5	0.5	10 ppm as N
Sulfate, ppm	36	36	250 ppm
Sodium, ppm	35	35	250 ppm
Chloramine	Detected	ND	5 ppm
Chlorine, ppm	Detected	ND	Detectable
Alkalinity, ppm	125	125	150 ppm
Total Dissolved Solids, ppm	200	200	500 ppm
Hardness, ppm	119	113	100 ppm
pH	7.6	7.5	6.5 – 8.5 ppm
Turbidity	0.00	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



**SELECTO SCIENTIFIC**  
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

[www.selectoinc.com](http://www.selectoinc.com)

[sales@selectoinc.com](mailto:sales@selectoinc.com)