

TECHNICAL SERVICE REPORT

Water Analysis

| | | | |
|---------------------------------------|------------------|-------------------------|-------------|
| Customer: | Location: | Date: | PO#: |
| Chick-fil-A | # 1054 | 2/21/08 | 304941 |
| Address: | | Tested By: | |
| 6408 W. Plano Pkwy Plano, TX 75093 | | AR | |
| Phone: | Email: | Selecto Contact: | |
| | | | |

| | |
|------------------------|--|
| Recommendation: | |
|------------------------|--|

ANALYTICAL RESULTS

| Evaluation of: | Unfiltered Water Sample | Filtered Water Sample | Recommended Max Levels |
|-----------------------------|--------------------------------|------------------------------|-------------------------------|
| Fluoride, ppm | 0.3 | 0.3 | 2 ppm |
| Chloride, ppm | 73 | 71 | 250 ppm |
| Nitrite, ppm | ND | ND | 1 ppm as N |
| Nitrate, ppm | 0.5 | 0.5 | 10 ppm as N |
| Sulfate, ppm | 87 | 87 | 250 ppm |
| Sodium, ppm | 55 | 52 | 250 ppm |
| Chloramine | Detected | Detected | .5 ppm |
| Chlorine, ppm | Detected | Detected | Detectable |
| Alkalinity, ppm | 120 | 120 | 150 ppm |
| Total Dissolved Solids, ppm | 300 | 290 | 500 ppm |
| Hardness, ppm | 171 | 169 | 100 ppm |
| pH | 7.5 | 7.5 | 6.5 – 8.5 ppm |
| Turbidity | 0.25 | 0.00 | .05 NTU |

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



SELECTO SCIENTIFIC
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

www.selectoinc.com
sales@selectoinc.com