

# TECHNICAL SERVICE REPORT

## Water Analysis

<b>Customer:</b>	<b>Location:</b>	<b>Date:</b>	<b>PO#:</b>
Chick-fil-A	# 2268	2/7/08	296726
<b>Address:</b>		<b>Tested By:</b>	
US Hwy 41 @ Williams Rd. Estero, FL 33928		AR	
<b>Phone:</b>	<b>Email:</b>	<b>Selecto Contact:</b>	

<b>Recommendation:</b>	
------------------------	--

### ANALYTICAL RESULTS

Evaluation of:	Walgreen Water Sample	Albertson Water Sample	Recommended Max Levels
Fluoride, ppm	0.1	0.1	2 ppm
Chloride, ppm	41	90	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.1	0.1	10 ppm as N
Sulfate, ppm	10	29	250 ppm
Sodium, ppm	55	76	250 ppm
Chloramine	Detected	Detected	.5 ppm
Chlorine, ppm	Detected	Detected	Detectable
Alkalinity, ppm	90	80	150 ppm
Total Dissolved Solids, ppm	170	280	500 ppm
Hardness, ppm	33	75	100 ppm
pH	6.8	7.7	6.5 – 8.5 ppm
Turbidity	3.2	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



**SELECTO SCIENTIFIC**  
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

[www.selectoinc.com](http://www.selectoinc.com)

[sales@selectoinc.com](mailto:sales@selectoinc.com)